



QUALITY CONTROL DISTRICT LABORATORY
KERALA WATER AUTHORITY
CANTONMENT P O, KOLLAM - 691 001

REPORT ON ANALYSIS OF WATER

Report No - 2024/QCDKLM/1294		Date: 11/03/2024		
Customer Name & Address		1. Date of Sample received: 06/03/2024		
WOODLEM PARK PUBLIC SCHOOL, CHERUKULAM.P.O, CHUNDA, ANCHAL, KOLLAM - 691 306 9061697307		2. Sampling done by: Customer		
		3. Sample Quantity : 250 ml		
		4. Source of Sample : Open Well Water		
		5. Sample Code : 2024/QCDKLM/1294		
		6. Test Performing Dates		
		From : 06/03/2024 To : 11/03/2024		
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT
2	E. coli /100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Authorized By

BACTERIOLOGIST

QUALITY CONTROL DISTRICT LAB
KERALA WATER AUTHORITY

Rev.No. 00 KOLLAM Date: 00

* End of Report *

Issue Date: 06.01.2024

Page 1 of 1

KWA/KLM/R/19 Issue No. 01
For WOODLEM PARK PUBLIC SCHOOL

MANAGER

PRINCIPAL
Woodlem Park Public School
Chunda, Cherukulam P.O,
Kollam-691306, Kerala India